


FIRE FACT NO. 040 CHECKLIST(s) : 06

TITLE : FIRE SEPARATION OF HAZARDOUS ROOMS

CHECKLIST ITEM(s) : 06-48, 50, 51, 52

REFERENCE(s) : 91-101/6-4.1.1

PAGE 1 of 1



*** 1 HOUR FIRE RESISTIVE SEPARATION MUST ALSO INCLUDE THE WALLS, CEILING AND FLOOR OF THE PROTECTED ROOM.**

